

Guardian Fall Protection, in accordance with ANSI/ISEA 125-2014, declares that the product(s) listed below is(are) in conformity with the requirements of the following standard(s):

Substrate/Fastener	Performance Standard	Conformity Level
I-beam with backer plate and bolts	ANSI Z359.18-2017, OSHA 1910, OSHA 1926 Subpart M	Level 2
Simulated concrete (7000 lbs) with (8) Hit-Z 1/2" bolts	ANSI Z359.18-2017, OSHA 1910, OSHA 1926 Subpart M	Level 2
Simulated metal roof 20 gauge in field with (40) 1/4 x 2" screws and spanner plate	ANSI Z359.18-2017, OSHA 1910, OSHA 1926 Subpart M	Level 2
Simulated metal roof 20 gauge in field with (40) 1/4" x 2" screws	OSHA 1910, OSHA 1926 Subpart M	Level 1
Simulated wood roof 5/8" in field with (40) 1/4" x 2" screws	OSHA 1910, OSHA 1926 Subpart M	Level 1

For Level 2 assessment, the ISO 17025-accredited test facility in which the product was tested is:

An independent third party

Owned or partially operated by an entity within Guardian Fall Protection's corporate structure, or within the manufacturing stream for this product, including subcontractors and subsuppliers.

Declaration Number: 18-0029
 Product Type: Type A Anchorage Connector
 Product Model(s): 00648, 00645, 00651, 10645, 10651, 10681

Test report reference

Number: 2018092100948

Date: 10/02/18

Authorized Signature: _____



Name (printed): Eric Helgeson

Title (printed): Regulatory & Quality Compliance Director

Date: 10/02/2018